

Page 1 of 2

Certificate No: LR2025079TA Issue Date: 13/10/2020 Expiry Date: 29/06/2025

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer Autronica Fire & Security AS

Address Bromstadvegen 59, Trondheim, 7047, Norway

Type Fire And Gas Detection Alarm And Control Systems

Description Fire detection and alarm system

AutroSafe 4 comprising following components:

BS-420 Fire alarm control panel BS-420M Fire alarm control panel BS-420G Fire alarm control panel BS-420G2 Fire alarm control panel

BC-420 Controller BC-440 Controller BS-430 Operator panel BU-420 Repeater panel BV-420 Repeater panel BP-405 Power Cabinet BPS-405 Power supply unit BPS-410 Power supply unit BSD-321 AutroFieldBus*

BU-110 Fire brigade loop panel* BV-110 Information loop panel*

Trade Name AutroSafe 4

Application Marine, offshore and industrial applications suitable for use in environmental

Thorsten Wolff

Senior Specialist to Lloyd's Register EMEA A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Page 2 of 2

Certificate No: LR2025079TA Issue Date: 13/10/2020 Expiry Date: 29/06/2025

Type Approval Certificate

categories ENV1, ENV2 and ENV3 as defined in Lloyd's Register's Type

Approval System, Test Specification Number 1 – 2013.

Specified Standard EN 54-2:1997+A1:200

EN54-4:1997+A1:2002+A2:2006

IACS unified requirements E10 (Rev.7 Oct 2018) except items marked with "*"

Additional Tests Low temperature test:(-15°C/16h) except BU-110, BV-110

Enclosurerating: IP32

Other Conditions Systems comprising the components described above are subject to a

separate plan appraisal according to applicable Rules and Regulations when

installed on LR classed vessels.

Items marked with "*" have to comply with IACS E10 Rev.7 when intended to be installed on ships contracted for construction on or after 1 January 2022.

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

The Design Appraisal Document No. HTS/ETS 40520-20/TW and its supplementary Type Approval Terms and Conditions form part of this Certificate.

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.