

Page 1 of 2

Certificate No: LR2184563TA Issue Date: 21/06/2021 Expiry Date: 31/12/2021

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer Autronica Fire & Security AS

Address Bromstadvegen 59, Trondheim, 7047

Type Fire Detection Alarm Systems

Description Ex barrier unit

Trade Name BZ-500 (HW Version 12.3)

Application Marine, offshore and industrial applications suitable for use in environmental

categories ENV1, ENV 2 and ENV3 as defined in Lloyd's Register's Type

Approval System, Test Specification Number 1 – March:2019

Specified Standard IEC 60092-504:2016

EN 54-18:2005 IACS E10 Rev.7

Other Conditions Ratings for application in hazardous areas are to be obtained from applicable

Ex Certificates.

Systems comprising the components described above are subject to a separate plan appraisal according to applicable Rules and Regulations when

installed on LR classed vessels.

Thorsten Wolff

Senior Specialist to Lloyd's Register EMEA A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Page 2 of 2

Certificate No: LR2184563TA Issue Date: 21/06/2021 Expiry Date: 31/12/2021

Type Approval Certificate

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

The Design Appraisal Document HTS/ETS 41047- 21 AHB/TW/AC and its supplementary Type Approval Terms and Conditions form part of this Certificate.

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.